

COMPANIA DE APA TARGOVISTE DAMBOVITA SA
DEPARTAMENTUL MANAGEMENT INTEGRAT CALITATE

Legea 458/2002(republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA TARGOVISTE

Laborator inregistrat la Ministerul Sanatatii - Certificat nr.662/25.07.2022 Str.Gaesti - Targoviste, Tel/Fax0245631472

BULETIN DE ANALIZE FIZICO – CHIMICE NR. 192

Solicitant: SECTIA TARGOVISTE Loc de prelevare: Valea Voevozilor, str. Tudor Vladimirescu, nr. 21, Magazin Domnescu Andreea 2020 Punct prelevare: robinet chiuveta magazin Cod proba: 700 Scopul analizei: verificarea calitatii apei – avarie electrica, ziua 1 Produs analizat: apa potabila Prelevat de: Oprea Elena	Fisa prelevare nr: 190 Data si ora prelevarii probei: 27.01.2023/13:05 Data si ora receptiei probei: 27.01.2023/14:10 Receptionat/inregistrat: chim. Tudorache Claudia Data si ora efectuării analizei: 27.01.2023/14:20 Data si ora finalizarii analizei: 27. 01.2023/16:10 Data si ora eliberării rezultatului: 30.01.2023/10:00
--	---

Metode de prelevare:ISO 5667-5/2017; SR EN ISO 5667-1/2022; SR EN ISO 5667-3/2018; SR EN ISO 5667-14/2017

Parametrii analizati	UM	Valoare CMA	Valoarea determinata	Metode de analiza
Concentratia ionilor de H	Unitati pH	$\geq 6,5 - \leq 9,5$	7,8/20,0°C	SR ISO 10523:2012
Conductivitate	$\mu S / cm$ la 20° C	2500	653	SR EN ISO 27888:1997
Turbiditate	NTU	≤ 5	0,23	SR EN ISO 7027-1:2016
Clor rezidual liber	mg/l	$\geq 0,1$ statie,rezervor $\geq 0,1 - \leq 0,5$ retea	0,30	SR EN ISO 7393-1:2002
Clor rezidual total	mg/l		0,32	SR EN ISO 7393-1:2002
Clor rezidual liber	%	min. 80% din clor total	94	-
Amoniu (NH ₄ ⁺)	mg/l	0,5	SLQ	SR ISO 7150-1:2001
Culoare	-	1)	1)	SR ISO 7887:2012 – metoda C
Miros	-	2)	2)	SR EN 1622:2007
Gust	-	3)	3)	SR EN 1622:2007
Nitrati (NO ₃ ⁻)	mg/l	50	-	SR ISO 7890-3:2000
Nitriti (NO ₂ ⁻)	mg/l	0,1 statie, rezervor 0,5 retea	-	SR ISO 26777:2002 SR EN 26777:2002/C91:2006
Mangan	$\mu g/l$	50	-	SR ISO 6333:1997
Fier (Fe ²⁺ ,Fe ³⁺)	$\mu g/l$	200	-	SR ISO 6332:1996/C91:2006
Suma de calciu si magneziu	Grade Germane	Minim 5	-	SR ISO 6059:2008
Indice de permanganat	mgO ₂ /l	5	-	SR EN ISO 8467:2001
Cloruri (Cl ⁻)	mg/l	250	-	SR ISO 9297:2001
Sulfati	mg/l	250	-	STAS 3069:1987

1)Acceptabila consumatorilor si nicio modificare anormala 2)Acceptabil consumatorilor si niciun miros anormal 3) Acceptabil consumatorilor si niciun gust anormal

*Notatia SLQ = “sub limita de cuantificare a metodei”; LQ: amoniu<0,020mg/l;

SEF LABORATOR,
Ing.chim.Sirbuletu Bogdan



RESPONSABIL ANALIZA,
Chim Tudorache Claudia

Reproducerea buletinului de analiza fara acceptul scris al laboratorului este INTERZISA!
Rezultatul analizelor se refera numai la proba prelevata si analizata.

COMPANIA DE APA TARGOVISTE DAMBOVITA SA
DEPARTAMENTUL MANAGEMENT INTEGRAT CALITATE

Legea 458/2002(republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA TARGOVISTE

Laborator inregistrat la Ministerul Sanatatii - Certificat nr. 662/25.07.2022 Str.Gaesti – Targoviste, Tel/fax.0245631472

BULETIN DE ANALIZA MICROBIOLOGICA NR.173

Solicitant: **SECTIA TARGOVISTE**

Loc de prelevare: Valea Voevozilor, str. Tudor Vladimirescu,
nr. 21, Magazin Domnescu Andreea 2020

Punct prelevare: robinet chiuveta magazin

Cod proba: 700

Scopul analizei: verificarea calitatii apei – avarie electrica,
ziua 1

Produs analizat: apa potabila

Prelevat de: Oprea Elena

Fisa prelevare nr: 190

Data si ora prelevarii probei: 27.01.2023/13:05

Data si ora receptiei probei: 27.01.2023/14:10

Receptionat/inregistrat: chim. Tudorache Claudia

Data si ora efectuării analizei: 27.01.2023/14:30

Data si ora finalizării analizei: 30.01.2023/ /12:00

Data si ora eliberării rezultatului: 30.01.2023/ /12:15

Metode de prelevare:ISO 5667-5/2017;SR EN ISO 5667-1/2022;SR EN ISO 5667-3/2018;SR EN ISO 19458/2007;SR EN ISO 5667-14/2017

PARAMETRII MICROBIOLOGICI

Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Escherichia coli	UFC/100ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Enterococi intestinali	UFC/100ml	0	0	SR EN ISO 7899-2/2002

PARAMETRII INDICATORI

Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Bacterii coliforme	UFC/100ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Nr. de colonii la 22°C	UFC/1 ml	Nicio modificare anormala	0	SR EN ISO 6222/2004
Nr. de colonii la 37°C	UFC/1 ml	Nicio modificare anormala	0	SR EN ISO 6222/2004

SEF LABORATOR,
Ing.chim.Sirbuletu Bogdan



RESPOSABIL ANALIZA,
Biolog Dutu Florina

Reproducerea buletinului de analiza fara acceptul scris al laboratorului este **INTERZISA!**
Rezultatul analizelor se refera numai la proba prelevata si analizata.

COMPANIA DE APA TARGOVISTE DAMBOVITA SA
DEPARTAMENTUL MANAGEMENT INTEGRAT CALITATE

Legea 458/2002(republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA TARGOVISTE

Laborator inregistrat la Ministerul Sanatatii - Certificat nr.662/25.07.2022 Str.Gaesti - Targoviste, Tel/Fax0245631472

BULETIN DE ANALIZE FIZICO – CHIMICE NR. 193

Solicitant: SECTIA TARGOVISTE Loc de prelevare: Manastirea Dealu Punct prelevare: robinet chiuveta bucatarie Cod proba: 701 Scopul analizei: verificarea calitatii apei – avarie electrica, ziua 1 Produs analizat: apa potabila Prelevat de: Oprea Elena	Fisa prelevare nr: 191 Data si ora prelevarii probei: 27.01.2023/13:25 Data si ora receptiei probei: 27.01.2023/14:10 Receptionat/inregistrat: chim. Tudorache Claudia Data si ora efectuării analizei: 27.01.2023/14:20 Data si ora finalizarii analizei: 27. 01.2023/16:10 Data si ora eliberării rezultatului: 30.01.2023/10:00
--	---

Metode de prelevare:ISO 5667-5/2017; SR EN ISO 5667-1/2022; SR EN ISO 5667-3/2018; SR EN ISO 5667-14/2017

Parametrii analizati	UM	Valoare CMA	Valoarea determinata	Metode de analiza
Concentratia ionilor de H	Unitati pH	$\geq 6,5 - \leq 9,5$	7,4/20,0°C	SR ISO 10523:2012
Conductivitate	$\mu S / cm$ la 20°C	2500	650	SR EN ISO 27888:1997
Turbiditate	NTU	≤ 5	0,22	SR EN ISO 7027-1:2016
Clor rezidual liber	mg/l	$\geq 0,1$ statie,rezervor $\geq 0,1 - \leq 0,5$ retea	0,19	SR EN ISO 7393-1:2002
Clor rezidual total	mg/l		0,21	SR EN ISO 7393-1:2002
Clor rezidual liber	%	min. 80% din clor total	90	-
Amoniu (NH ₄ ⁺)	mg/l	0,5	SLQ	SR ISO 7150-1:2001
Culoare	-	1)	1)	SR ISO 7887:2012 – metoda C
Miros	-	2)	2)	SR EN 1622:2007
Gust	-	3)	3)	SR EN 1622:2007
Nitrati (NO ₃ ⁻)	mg/l	50	-	SR ISO 7890-3:2000
Nitriti (NO ₂ ⁻)	mg/l	0,1 statie, rezervor 0,5 retea	-	SR ISO 26777:2002 SR EN 26777:2002/C91:2006
Mangan	$\mu g/l$	50	-	SR ISO 6333:1997
Fier (Fe ²⁺ ,Fe ³⁺)	$\mu g/l$	200	-	SR ISO 6332:1996/C91:2006
Suma de calciu si magneziu	Grade Germane	Minim 5	-	SR ISO 6059:2008
Indice de permanganat	mgO ₂ /l	5	-	SR EN ISO 8467:2001
Cloruri (Cl ⁻)	mg/l	250	-	SR ISO 9297:2001
Sulfati	mg/l	250	-	STAS 3069:1987

1)Acceptabila consumatorilor si nicio modificare anormala 2)Acceptabil consumatorilor si niciun miros anormal 3) Acceptabil consumatorilor si niciun gust anormal

*Notatia SLQ = "sub limita de cuantificare a metodei"; LQ: amoniu<0,020mg/l;

SEF LABORATOR,
Ing.chim.Sirbuletu Bogdan



RESPONSABIL ANALIZA,
Chim Tudorache Claudia

Reproducerea buletinului de analiza fara acceptul scris al laboratorului este INTERZISA!
Rezultatul analizelor se refera numai la proba prelevata si analizata.

COMPANIA DE APA TARGOVISTE DAMBOVITA SA
DEPARTAMENTUL MANAGEMENT INTEGRAT CALITATE

Legea 458/2002(republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA TARGOVISTE

Laborator inregistrat la Ministerul Sanatatii - Certificat nr. 662/25.07.2022 Str.Gaesti – Targoviste, Tel/fax.0245631472

BULETIN DE ANALIZA MICROBIOLOGICA NR.174

Solicitant: **SECTIA TARGOVISTE**

Loc de prelevare: **Manastirea Dealu**

Punct prelevare: **robinet chiuveta bucatarie**

Cod proba: **701**

Scopul analizei: **verificarea calitatii apei – avarie electrica, ziua 1**

Produs analizat: **apa potabila**

Prelevat de: **Oprea Elena**

Fisa prelevare nr: **191**

Data si ora prelevarii probei: **27.01.2023/13:25**

Data si ora receptiei probei: **27.01.2023/14:10**

Receptionat/inregistrat: **chim. Tudorache Claudia**

Data si ora efectuării analizei: **27.01.2023/14:30**

Data si ora finalizării analizei: **30.01.2023/ /12:00**

Data si ora eliberării rezultatului: **30.01.2023/ /12:15**

Metode de prelevare: **ISO 5667-5/2017;SR EN ISO 5667-1/2022;SR EN ISO 5667-3/2018;SR EN ISO 19458/2007;SR EN ISO 5667-14/2017**

PARAMETRII MICROBIOLOGICI

Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Escherichia coli	UFC/100ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Enterococi intestinali	UFC/100ml	0	0	SR EN ISO 7899-2/2002

PARAMETRII INDICATORI

Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Bacterii coliforme	UFC/100ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Nr. de colonii la 22°C	UFC/1 ml	Nicio modificare anormala	0	SR EN ISO 6222/2004
Nr. de colonii la 37°C	UFC/1 ml	Nicio modificare anormala	0	SR EN ISO 6222/2004

SEF LABORATOR,
Ing.chim.Sirbuleta Bogdan



RESPOSABIL ANALIZA,
Biolog Dutu Florina

Reproducerea buletinului de analiza fara acceptul scris al laboratorului este **INTERZISA!**
Rezultatul analizelor se refera numai la proba prelevata si analizata.