

COMPANIA DE APA TARGOVISTE DAMBOVITA S.A.**DEPARTAMENT MANAGEMENT INTEGRAT CALITATE****LABORATOR CENTRAL APA POTABILA**

Legea 458/2002(republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA PUCIOASA

Laborator inregistrat la Ministerul Sanatatii - Certificat nr. 592/24.10.2022, str.Debarcaderului nr.1-Pucioasa,Tel/Fax 0245762640

BULETIN DE ANALIZE FIZICO – CHIMICE NR. 160

Solicitant: Sectia Pucioasa Loc de prelevare: Varfuri-Sat Suvita, nr.120, fam.Varjoghe Ion Punct de prelevare: robinet cismea curte Cod proba: 64 Scopul analizei: verificarea calitatii apei-monitorizare avarie retea Produs analizat: apa potabila Prelevat de: Virlan G.	Fisa prelevare nr: 224 Data si ora prelevarii probei: 01.02.2023/14:45 Data si ora receptiei probei: 01.02.2023/15:30 Receptionat/inregistrat de: Dinescu G. Data si ora efectuarii analizei: 01.02.2023/15:40 Data si ora finalizarii analizei: 01.02.2023/18:50 Data si ora eliberarii rezultatului: 02.02.2023/10:00
---	--

Metode de prelevare:ISO 5667-5/2017; SR EN ISO 5667-1/2022; SR EN ISO 5667-3/2018; SR EN ISO 5667-14/2017

Parametrii analizati	UM	Valoare CMA	Valoarea determinata	Metode de analiza
Concentratia ionilor de H	Unitati pH	$\geq 6,5 - \leq 9,5$	7,6(20°C)	SR EN ISO 10523:2012
Conductivitate	$\mu S / cm$ la 20°C	2500	647	SR EN 27888:1997
Turbiditate	NTU	≤ 5	1,55	SR EN ISO 7027-1:2016
Clor rezidual liber	mg/l	$\geq 0,1$ statie,rezervor $\geq 0,1 - \leq 0,5$ retea	0,44	SR EN ISO 7393-1:2002
Clor rezidual total	mg/l		0,48	SR EN ISO 7393-1:2002
% clor rezidual liber din clorul rezidual total	%	Min.80	92	
Amoniu (NH_4^+)	mg/l	0,5	SLQ	SR ISO 7150-1:2001
Culoare	-	1)	1	SR EN ISO 7887:2012-metoda C
Miros	-	2)	2	SR EN 1622:2007
Gust	-	3)	3	SR EN 1622:2007
Aluminiu	$\mu g/l$	200	-	SR ISO 10566:2001
Nitrati(NO_3^-)	mg/l	50	-	SR ISO 7890-3:2000
Nitriti (NO_2^-)	mg/l	0,1 statie,rezervor 0,5 retea	-	SR EN 26777:2002 SR EN 26777:2002/C91:2006
Mangan	$\mu g/l$	50	-	SR ISO 6333:1997
Fier (Fe^{2+}, Fe^{3+})	$\mu g/l$	200	-	SR ISO 6332:1996/C91:2006
Suma de calciu si magneziu	Grade Germane	Minim 5	-	SR ISO 6059:2008
Indice de permanganat	mgO_2/l	5	-	SR EN ISO 8467:2001
Cloruri (Cl^-)	mg/l	250	-	SR ISO 9297:2001
Sulfati	mg/l	250	-	STAS 3069:1987

1)Acceptabila consumatorilor si nicio modificare anormala; 2)Acceptabil consumatorilor si niciun miros anormal; 3) Acceptabil consumatorilor si niciun gust anormal

*Notatia SLQ="sub limita de cuantificare a metodei"

*LQ: amoniu <0,019 mg/l

SEF LABORATOR
Ch. Dimian ClaudiaRESPONSABIL ANALIZA
Ch. Dimian Claudia

Cod F-17-6/2

Reproducerea buletinului de analiza fara acceptul scris al laboratorului este interzisa!
Rezultatele analizelor se refera numai la proba prelevata si analizata.

COMPANIA DE APA TARGOVISTE DAMBOVITA S.A.**DEPARTAMENT MANAGEMENT INTEGRAT CALITATE****LABORATOR CENTRAL APA POTABILA**

Legea 458/2002(republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA PUCIOASA

Laborator inregistrat la Ministerul Sanatatii - Certificat nr. 592/24.10.2022, str.Debarcaderului nr.1-Pucioasa,Tel/Fax 0245762640

BULETIN DE ANALIZE MICROBIOLOGICE NR.152

Solicitant: Sectia Pucioasa Loc de prelevare: Varfuri-Sat Suvita, nr.120, fam.Varjoghe Ion Punct de prelevare: robinet cisterna curte Cod proba: 64 Scopul analizei: verificarea calitatii apei-monitorizare avarie retea Produs analizat: apa potabila Prelevat de: Virlan G.	Fisa prelevare nr: 224 Data si ora prelevării probei: 01.02.2023/14:45 Data si ora receptiei probei: 01.02.2023/15:30 Receptionat/inregistrat de: Dinescu G. Data si ora efectuării analizei: 01.02.2023/17:00 Data si ora finalizării analizei: 04.02.2023/10:00 Data si ora eliberării rezultatului: 04.02.2023/10:10 Correspondent cu buletin analiza fizico-chimica nr. 160
Metode de prelevare : ISO 5667-5/2017;SR EN ISO 5667-1/2022;SR EN ISO 5667-3/2018;SR EN ISO 19458/2007;SR EN ISO 5667-14/2017	

PARAMETRII MICROBIOLOGICI DE CALITATE AI APEI POTABILE

Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Escherichia coli	UFC/100 ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Enterococi intestinali	UFC/100 ml	0	0	SR EN ISO 7899-2/2002

PARAMETRII INDICATORI

Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Bacterii coliforme	UFC/100 ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Nr. de colonii la 22°C	UFC/ 1ml	Nicio modificare anormala	0	SR EN ISO 6222/2004
Nr. de colonii la 37°C	UFC/ 1ml	Nicio modificare anormala	2	SR EN ISO 6222/2004
Clostridium perfringens	UFC/100 ml	0	-	SR EN ISO 14189/2017

SEF LABORATOR
Ch. Dimian ClaudiaRESPONSABIL ANALIZA
Biolog Manoiu Mirabela

Cod F-17-7/2

Reproducerea buletinului de analiza fara acceptul scris al laboratorului este interzisa!
Rezultatele analizelor se refera numai la proba prelevata si analizata.

COMPANIA DE APA TARGOVISTE DAMBOVITA S.A.**DEPARTAMENT MANAGEMENT INTEGRAT CALITATE****LABORATOR CENTRAL APA POTABILA**

Legea 458/2002(republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA PUCIOASA

Laborator inregistrat la Ministerul Sanatatii - Certificat nr. 592/24.10.2022, str.Debarcaderului nr.1-Pucioasa,Tel/Fax 0245762640

BULETIN DE ANALIZE FIZICO – CHIMICE NR. 161

Solicitant: Sectia Pucioasa Loc de prelevare: Varfuri-Sat Suvita, nr.80, fam.David Petrut Punct de prelevare: robinet cismea curte Cod proba: 65 Scopul analizei: verificarea calitatii apei-monitorizare avarie retea Produs analizat: apa potabila Prelevat de: Virilan G.	Fisa prelevare nr: 225 Data si ora prelevarii probei: 01.02.2023/15:00 Data si ora receptiei probei: 01.02.2023/15:30 Receptionat/inregistrat de: Dinescu G. Data si ora efectuarii analizei: 01.02.2023/15:40 Data si ora finalizarii analizei: 01.02.2023/18:50 Data si ora eliberarii rezultatului: 02.02.2023/10:00
---	--

Metode de prelevare:ISO 5667-5/2017; SR EN ISO 5667-1/2022; SR EN ISO 5667-3/2018; SR EN ISO 5667-14/2017

Parametrii analizati	UM	Valoare CMA	Valoarea determinata	Metode de analiza
Concentratia ionilor de H	Unitati pH	$\geq 6,5 - \leq 9,5$	7,7(20°C)	SR EN ISO 10523:2012
Conductivitate	$\mu S / cm$ la 20°C	2500	648	SR EN 27888:1997
Turbiditate	NTU	≤ 5	1,47	SR EN ISO 7027-1:2016
Clor rezidual liber	mg/l	$\geq 0,1$ statie,rezervor $\geq 0,1 - \leq 0,5$ retea	0,46	SR EN ISO 7393-1:2002
Clor rezidual total	mg/l		0,50	SR EN ISO 7393-1:2002
% clor rezidual liber din clorul rezidual total	%	Min.80	92	
Amoniu (NH_4^+)	mg/l	0,5	SLQ	SR ISO 7150-1:2001
Culoare	-	1)	1	SR EN ISO 7887:2012-metoda C
Miros	-	2)	2	SR EN 1622:2007
Gust	-	3)	3	SR EN 1622:2007
Aluminiu	$\mu g/l$	200	-	SR ISO 10566:2001
Nitrati(NO_3^-)	mg/l	50	-	SR ISO 7890-3:2000
Nitriti (NO_2^-)	mg/l	0,1 statie,rezervor 0,5 retea	-	SR EN 26777:2002 SR EN 26777:2002/C91:2006
Mangan	$\mu g/l$	50	-	SR ISO 6333:1997
Fier (Fe^{2+}, Fe^{3+})	$\mu g/l$	200	-	SR ISO 6332:1996/C91:2006
Suma de calciu si magneziu	Grade Germane	Minim 5	-	SR ISO 6059:2008
Indice de permanganat	mgO_2/l	5	-	SR EN ISO 8467:2001
Cloruri (Cl^-)	mg/l	250	-	SR ISO 9297:2001
Sulfati	mg/l	250	-	STAS 3069:1987

1)Acceptabila consumatorilor si nicio modificare anormala; 2)Acceptabil consumatorilor si niciun miros anormal; 3) Acceptabil consumatorilor si niciun gust anormal

*Notatia SLQ="sub limita de cuantificare a metodei"

*LQ: amoniu <0,019 mg/l

SEF LABORATOR
Ch. Dimian ClaudiaRESPONSABIL ANALIZA
Ch. Dimian Claudia

Cod F-17-6/2

Reproducerea buletinului de analiza fara acceptul scris al laboratorului este interzisa!
Rezultatele analizelor se refera numai la proba prelevata si analizata.

COMPANIA DE APA TARGOVISTE DAMBOVITA S.A.**DEPARTAMENT MANAGEMENT INTEGRAT CALITATE****LABORATOR CENTRAL APA POTABILA**

Legea 458/2002(republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA PUCIOASA

Laborator inregistrat la Ministerul Sanatatii - Certificat nr. 592/24.10.2022, str.Debarcaderului nr.1-Pucioasa,Tel/Fax 0245762640

BULETIN DE ANALIZE MICROBIOLOGICE NR.153


Solicitant: Sectia Pucioasa Loc de prelevare: Varfuri-Sat Suvita, nr.80, fam.David Petrut Punct de prelevare: robinet cisterna curte Cod proba: 65 Scopul analizei: verificarea calitatii apei-monitorizare avarie retea Produs analizat: apa potabila Prelevat de: Virlan G.	Fisa prelevare nr: 225 Data si ora prelevarii probei: 01.02.2023/15:00 Data si ora receptiei probei: 01.02.2023/15:30 Receptionat/inregistrat de: Dinescu G. Data si ora efectuării analizei: 01.02.2023/17:00 Data si ora finalizării analizei: 04.02.2023//10:00 Data si ora eliberării rezultatului: 04.02.2023/10:10 Correspondent cu buletin analiza fizico-chimica nr. 161
Metode de prelevare : ISO 5667-5/2017;SR EN ISO 5667-1/2022;SR EN ISO 5667-3/2018;SR EN ISO 19458/2007;SR EN ISO 5667-14/2017	

PARAMETRII MICROBIOLOGICI DE CALITATE AI APEI POTABILE

Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Escherichia coli	UFC/100 ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Enterococi intestinali	UFC/100 ml	0	0	SR EN ISO 7899-2/2002

PARAMETRII INDICATORI

Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Bacterii coliforme	UFC/100 ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Nr. de colonii la 22°C	UFC/ 1ml	Nicio modificare anormala	4	SR EN ISO 6222/2004
Nr. de colonii la 37°C	UFC/ 1ml	Nicio modificare anormala	0	SR EN ISO 6222/2004
Clostridium perfringens	UFC/100 ml	0	-	SR EN ISO 14189/2017

SEF LABORATOR
Ch. Dimian ClaudiaRESPONSABIL ANALIZA
Biolog Manoiu Mirabela

Cod F-17-7/2

Reproducerea buletinului de analiza fara acceptul scris al laboratorului este interzisa!
Rezultatele analizelor se refera numai la proba prelevata si analizata.

COMPANIA DE APA TARGOVISTE DAMBOVITA S.A.**DEPARTAMENT MANAGEMENT INTEGRAT CALITATE****LABORATOR CENTRAL APA POTABILA**

Legea 458/2002(republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA PUCIOASA

Laborator inregistrat la Ministerul Sanatatii - Certificat nr. 592/24.10.2022, str.Debarcaderului nr.1-Pucioasa,Tel/Fax 0245762640

BULETIN DE ANALIZE FIZICO – CHIMICE NR. 168

Solicitant: Sectia Pucioasa Loc de prelevare: Varfuri-Sat Suvita, nr.120, fam.Varjoghe Ion Punct de prelevare: robinet cismea curte Cod proba: 64 Scopul analizei: verificarea calitatii apei-monitorizare avarie retea Produs analizat: apa potabila Prelevat de: Virlan G.	Fisa prelevare nr: 234 Data si ora prelevarii probei: 02.02.2023/10:30 Data si ora receptiei probei: 02.02.2023/13:15 Receptionat/inregistrat de: Hategan E. Data si ora efectuarii analizei: 02.02.2023/13:30 Data si ora finalizarii analizei: 02.02.2023/15:30 Data si ora eliberarii rezultatului: 03.02.2023/11:00
---	--


Metode de prelevare:ISO 5667-5/2017; SR EN ISO 5667-1/2022; SR EN ISO 5667-3/2018; SR EN ISO 5667-14/2017

Parametrii analizati	UM	Valoare CMA	Valoarea determinata	Metode de analiza
Concentratia ionilor de H	Unitati pH	$\geq 6,5 - \leq 9,5$	7,6(20°C)	SR EN ISO 10523:2012
Conductivitate	$\mu S / cm$ la 20°C	2500	637	SR EN 27888:1997
Turbiditate	NTU	≤ 5	0,24	SR EN ISO 7027-1:2016
Clor rezidual liber	mg/l	$\geq 0,1$ statie,rezervor $\geq 0,1 - \leq 0,5$ retea	0,43	SR EN ISO 7393-1:2002
Clor rezidual total	mg/l		0,47	SR EN ISO 7393-1:2002
% clor rezidual liber din clorul rezidual total	%	Min.80	91	
Amoniu (NH_4^+)	mg/l	0,5	SLQ	SR ISO 7150-1:2001
Culoare	-	1)	1	SR EN ISO 7887:2012-metoda C
Miros	-	2)	2	SR EN 1622:2007
Gust	-	3)	3	SR EN 1622:2007
Aluminiu	$\mu g/l$	200	-	SR ISO 10566:2001
Nitrati(NO_3^-)	mg/l	50	-	SR ISO 7890-3:2000
Nitriti (NO_2^-)	mg/l	0,1 statie,rezervor 0,5 retea	-	SR EN 26777:2002 SR EN 26777:2002/C91:2006
Mangan	$\mu g/l$	50	-	SR ISO 6333:1997
Fier (Fe^{2+}, Fe^{3+})	$\mu g/l$	200	-	SR ISO 6332:1996/C91:2006
Suma de calciu si magneziu	Grade Germane	Minim 5	-	SR ISO 6059:2008
Indice de permanganat	mgO_2/l	5	-	SR EN ISO 8467:2001
Cloruri (Cl^-)	mg/l	250	-	SR ISO 9297:2001
Sulfati	mg/l	250	-	STAS 3069:1987

1)Acceptabila consumatorilor si nicio modificare anormala; 2)Acceptabil consumatorilor si niciun miros anormal; 3) Acceptabil consumatorilor si niciun gust anormal

*Notatia SLQ="sub limita de cuantificare a metodei"

*LQ: amoniu <0,019 mg/l

SEF LABORATOR
Ch. Dimian ClaudiaRESPONSABIL ANALIZA
Ch. Dimian Claudia

Cod F-17-6/2

Reproducerea buletinului de analiza fara acceptul scris al laboratorului este interzisa!
Rezultatele analizelor se refera numai la proba prelevata si analizata.

COMPANIA DE APA TARGOVISTE DAMBOVITA S.A.

DEPARTAMENT MANAGEMENT INTEGRAT CALITATE

LABORATOR CENTRAL APA POTABILA

Legea 458/2002(republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA PUCIOASA

Laborator inregistrat la Ministerul Sanatatii - Certificat nr. 592/24.10.2022, str.Debarcaderului nr.1-Pucioasa,Tel/Fax 0245762640

BULETIN DE ANALIZE MICROBIOLOGICE NR.160

Solicitant: Sectia Pucioasa Loc de prelevare: Varfuri-Sat Suvita, nr.120, fam.Varjoghe Ion Punct de prelevare: robinet cisterna curte Cod proba: 64 Scopul analizei: verificarea calitatii apei-monitorizare avarie retea Produs analizat: apa potabila Prelevat de: Virlian G.	Fisa prelevare nr: 234 Data si ora prelevarii probei: 02.02.2023/10:30 Data si ora receptiei probei: 02.02.2023/13:15 Receptionat/inregistrat de: Hategan E. Data si ora efectuării analizei: 02.02.2023/15:00 Data si ora finalizării analizei: 05.02.2023//08:00 Data si ora eliberării rezultatului: 06.02.2023/09:00 Correspondent cu buletin analiza fizico-chimica nr. 168
Metode de prelevare :ISO 5667-5/2017;SR EN ISO 5667-1/2022;SR EN ISO 5667-3/2018;SR EN ISO 19458/2007;SR EN ISO 5667-14/2017	

PARAMETRII MICROBIOLOGICI DE CALITATE AI APEI POTABILE


Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Escherichia coli	UFC/100 ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Enterococi intestinali	UFC/100 ml	0	0	SR EN ISO 7899-2/2002

PARAMETRII INDICATORI

Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Bacterii coliforme	UFC/100 ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Nr. de colonii la 22°C	UFC/ 1ml	Nicio modificare anormala	1	SR EN ISO 6222/2004
Nr. de colonii la 37°C	UFC/ 1ml	Nicio modificare anormala	2	SR EN ISO 6222/2004
Clostridium perfringens	UFC/100 ml	0	-	SR EN ISO 14189/2017

SEF LABORATOR
Ch. Dimian Claudia

2



RESPONSABIL ANALIZA
Biolog Manoiu Mirabela

3

Cod F-17-7/2

Reproducerea buletinului de analiza fara acceptul scris al laboratorului este interzisa!
Rezultatele analizelor se refera numai la proba prelevata si analizata.

COMPANIA DE APA TARGOVISTE DAMBOVITA S.A.**DEPARTAMENT MANAGEMENT INTEGRAT CALITATE****LABORATOR CENTRAL APA POTABILA**

Legea 458/2002(republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA PUCIOASA

Laborator inregistrat la Ministerul Sanatatii - Certificat nr. 592/24.10.2022, str.Debarcaderului nr.1-Pucioasa,Tel/Fax 0245762640

BULETIN DE ANALIZE FIZICO – CHIMICE NR. 169

Solicitant: Sectia Pucioasa Loc de prelevare: Varfuri-Sat Suvita, nr.80, fam.David Petrut Punct de prelevare: robinet cisterna curte Cod proba: 65 Scopul analizei: verificarea calitatii apei-monitorizare avarie retea Produs analizat: apa potabila Prelevat de: Virlan G.	Fisa prelevare nr: 235 Data si ora prelevarii probei: 02.02.2023/10:45 Data si ora receptiei probei: 02.02.2023/13:15 Receptionat/inregistrat de: Hategan E. Data si ora efectuarii analizei: 02.02.2023/13:30 Data si ora finalizarii analizei: 02.02.2023/15:30 Data si ora eliberarii rezultatului: 03.02.2023/11:00
--	--


Metode de prelevare:ISO 5667-5/2017; SR EN ISO 5667-1/2022; SR EN ISO 5667-3/2018; SR EN ISO 5667-14/2017

Parametrii analizati	UM	Valoare CMA	Valoarea determinata	Metode de analiza
Concentratia ionilor de H	Unitati pH	$\geq 6,5 - \leq 9,5$	7,6(20°C)	SR EN ISO 10523:2012
Conductivitate	$\mu S / cm$ la 20°C	2500	639	SR EN 27888:1997
Turbiditate	NTU	≤ 5	0,38	SR EN ISO 7027-1:2016
Clor rezidual liber	mg/l	$\geq 0,1$ statie,rezervor $\geq 0,1 - \leq 0,5$ retea	0,45	SR EN ISO 7393-1:2002
Clor rezidual total	mg/l		0,50	SR EN ISO 7393-1:2002
% clor rezidual liber din clorul rezidual total	%	Min.80	90	
Amoniu (NH_4^+)	mg/l	0,5	SLQ	SR ISO 7150-1:2001
Culoare	-	1)	1	SR EN ISO 7887:2012-metoda C
Miros	-	2)	2	SR EN 1622:2007
Gust	-	3)	3	SR EN 1622:2007
Aluminiu	$\mu g/l$	200	-	SR ISO 10566:2001
Nitrati(NO_3^-)	mg/l	50	-	SR ISO 7890-3:2000
Nitriti (NO_2^-)	mg/l	0,1 statie,rezervor 0,5 retea	-	SR EN 26777:2002 SR EN 26777:2002/C91:2006
Mangan	$\mu g/l$	50	-	SR ISO 6333:1997
Fier (Fe^{2+}, Fe^{3+})	$\mu g/l$	200	-	SR ISO 6332:1996/C91:2006
Suma de calciu si magneziu	Grade Germane	Minim 5	-	SR ISO 6059:2008
Indice de permanganat	mgO_2/l	5	-	SR EN ISO 8467:2001
Cloruri (Cl^-)	mg/l	250	-	SR ISO 9297:2001
Sulfati	mg/l	250	-	STAS 3069:1987

1)Acceptabila consumatorilor si nicio modificare anormala; 2)Acceptabil consumatorilor si niciun miros anormal; 3) Acceptabil consumatorilor si niciun gust anormal

*Notatia SLQ="sub limita de cuantificare a metodei"

*LQ: amoniu <0,019 mg/l

SEF LABORATOR
Ch. Dimian ClaudiaRESPONSABIL ANALIZA
Ch. Dimian Claudia

Cod F-17-6/2

Reproducerea buletinului de analiza fara acceptul scris al laboratorului este interzisa!
Rezultatele analizelor se refera numai la proba prelevata si analizata.

COMPANIA DE APA TARGOVISTE DAMBOVITA S.A.

DEPARTAMENT MANAGEMENT INTEGRAT CALITATE

LABORATOR CENTRAL APA POTABILA

Legea 458/2002(republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA PUCIOASA

Laborator inregistrat la Ministerul Sanatatii - Certificat nr. 592/24.10.2022, str.Debarcaderului nr.1-Pucioasa,Tel/Fax 0245762640

BULETIN DE ANALIZE MICROBIOLOGICE NR.161

Solicitant: Sectia Pucioasa Loc de prelevare: Varfuri-Sat Suvita, nr.80, fam.David Petrut Punct de prelevare: robinet cismea curte Cod proba: 65 Scopul analizei: verificarea calitatii apei-monitorizare avarie retea Produs analizat: apa potabila Prelevat de: Virlan G.	Fisa prelevare nr: 235 Data si ora prelevarii probei: 02.02.2023/10:45 Data si ora receptiei probei: 02.02.2023/13:15 Receptionat/inregistrat de: Hategan E. Data si ora efectuării analizei: 02.02.2023/15:00 Data si ora finalizarii analizei: 05.02.2023//08:00 Data si ora eliberării rezultatului: 06.02.2023/09:00 Correspondent cu buletin analiza fizico-chimica nr. 169
Metode de prelevare : ISO 5667-5/2017;SR EN ISO 5667-1/2022;SR EN ISO 5667-3/2018;SR EN ISO 19458/2007;SR EN ISO 5667-14/2017	

PARAMETRII MICROBIOLOGICI DE CALITATE AI APEI POTABILE


Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Escherichia coli	UFC/100 ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Enterococi intestinali	UFC/100 ml	0	0	SR EN ISO 7899-2/2002

PARAMETRII INDICATORI

Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Bacterii coliforme	UFC/100 ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Nr. de colonii la 22°C	UFC/ 1ml	Nicio modificare anormala	2	SR EN ISO 6222/2004
Nr. de colonii la 37°C	UFC/ 1ml	Nicio modificare anormala	0	SR EN ISO 6222/2004
Clostridium perfringens	UFC/100 ml	0	-	SR EN ISO 14189/2017

SEF LABORATOR
Ch. Dimian Claudia

2



RESPONSABIL ANALIZA
Biolog Manoiu Mirabela

3

Cod F-17-7/2

Reproducerea buletinului de analiza fara acceptul scris al laboratorului este interzisa!
Rezultatele analizelor se refera numai la proba prelevata si analizata.