

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE SEMESTRUL AL DOILEA 2021

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **PARC INDUSTRIAL PRIBOIU** – SEPTEMBRIE 2021

Tip proba-apa uzata

Indicator analizat	Punct de prelevare	U.M.	Val. inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. AMnr.30/14.06.2018	Metoda de analiza (STAS, ISO)
pH	Iesire statie	unitati ph	7.4	-	-	1	0	6.5-8.5	SR ISO 10523/2012
MTS		mg/l	30	-	-	1	0	60	SR EN 872/2005
CBO ₅		mg/l	5	-	-	1	0	25	SR EN 1899-1/2003
CCO-Cr		mg/l	<30	-	-	1	0	125	SR ISO 6060/96
SE		mg/l	< 20	-	-	1	0	20	SR 7587/96
Reziduu fix		mg/l	410	-	-	1	0	2000	STAS 9187/84
Detergenti		mg/l	<0.1	-	-	1	0	0.5	SR EN 903/2003
Fosfor total		mg/l	1.65	-	-	1	0	2	SR EN ISO 6878/2005
Azot total		mg/l	22	-	-	1	1	15	SR EN 12260/2008
Amoniu		mg/l	0.28	-	-	1	0	3	SR ISO-1/2001
Azotati		mg/l	99	-	-	1	1	37	SR EN ISO 10304-1/2009
Cloruri		mg/l	160	-	-	1	0	500	SR EN ISO 10304-1/2009

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare – Nr. 1152/13.09.2021