

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL AL TREILEA 2021

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **PETRESTI** - IULIE 2021

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr. masuratori	Nr. depasiri CMA sau VL	CMA/VL conform AM nr. 9030 din 16.05.2013	Metoda de analiza (STAS,ISO)
Ph	lesire statie	Unitati pH	7,5	–	–	1	0	6,5 – 8,5	SR ISO 10523/2012
CCO	lesire statie	mg/l	< 30	–	–	1	0	125	SR ISO 6060:1996
Amoniu	lesire statie	mg/l	1,50	–	–	1	0	2	SR ISO 7150-1:2001
Agenti de suprafata anionici	lesire statie	mg/l	0,20	–	–	1	0	0,5	SR EN 903:2003
MTS	lesire statie	mg/l	6,8	–	–	1	0	60	SR EN 872:2005
Reziduu filtrabil	lesire statie	mg/l	241	–	–	1	0	2000	STAS 9187:1984
CBO5	lesire statie	mg/l	5	–	–	1	0	25	SR EN 1899-1:2003
Substanta extractibila	lesire statie	mg/l	< 20	–	–	1	0	20	SR 7587:1996

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare – Nr. 915/19.07.2021

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **PETRESTI** - AUGUST 2021

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr. masurat ori	Nr. depasiri CMA sau VL	CMA/VL conform AM nr. 9030 din 16.05.2013	Metoda de analiza (STAS,ISO)
Ph	lesire statie	Unitati pH	7,9	–	–	1	0	6,5 – 8,5	SR ISO 10523/2012
CCO	lesire statie	mg/l	< 30	–	–	1	0	125	SR ISO 6060:1996
Amoniu	lesire statie	mg/l	1,41	–	–	1	0	2	SR ISO 7150-1:2001
Agenti de suprafata anionici	lesire statie	mg/l	0,23	–	–	1	0	0,5	SR EN 903:2003
MTS	lesire statie	mg/l	7,0	–	–	1	0	60	SR EN 872:2005
Reziduu filtrabil	lesire statie	mg/l	265	–	–	1	0	2000	STAS 9187:1984
CBO5	lesire statie	mg/l	5	–	–	1	0	25	SR EN 1899-1:2003

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

www.catd.ro secretariat@catd.ro

Substanta extractibila	lesire statie	mg/l	< 20	-	-	1	0	20	SR 7587:1996
------------------------	---------------	------	------	---	---	---	---	----	--------------

CMA - concentratie maxima admisa sau VL – valoare limita


U.M. - unitate de masura

Conform Raport de incercare – Nr. 1038/17.08.2021

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **PETRESTI** - SEPTEMBRIE 2021

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr. masuratori	Nr. depasiri CMA sau VL	CMA/VL conform AM nr. 9030 din 16.05.2013	Metoda de analiza (STAS,ISO)
Ph	lesire statie	Unitati pH	7,7	-	-	1	0	6,5 – 8,5	SR ISO 10523/2012
CCO	lesire statie	mg/l	< 30	-	-	1	0	125	SR ISO 6060:1996
Amoniu	lesire statie	mg/l	1,07	-	-	1	0	2	SR ISO 7150-1:2001
Agenti de suprafata anionici	lesire statie	mg/l	0,16	-	-	1	0	0,5	SR EN 903:2003
MTS	lesire statie	mg/l	4,8	-	-	1	0	60	SR EN 872:2005
Reziduu filtrabil	lesire statie	mg/l	234	-	-	1	0	2000	STAS 9187:1984



COMPANIA DE APA TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

www.catd.ro secretariat@catd.ro

CBO5	lesire statie	mg/l	5	-	-	1	0	25	SR EN 1899-1:2003
Substanta extractibila	lesire statie	mg/l	< 20	-	-	1	0	20	SR 7587:1996

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare – Nr. 1200/20.09.2021