



## REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL AL TREILEA 2021

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **POIANA**- SEPTEMBRIE 2021

Tip proba-apa uzata

Indicator de analiza	Punct de Prelevare	U.M	Valoare inregistrata	Valoare maxima	Valoare minima	Numar masurat ori	Nr.depa siri CMA / VL	CMA/VL conform autorizatiei de mediu Nr.AGA nr.81/16.03.2021	Metoda de analiza
PH	lesire statie	Unit/PH	7,7	-	-	1	0	6,5-8,5	SR EN ISO10523-2012
CCO-CR	lesire statie	mg/l	<30	-	-	1	0	125	SR ISO 6060/96
Agenti de suprafata anionici	lesire statie	mg/l	<0,1	-	-	1	0	0,5	SR EN 903:2003
MTS	lesire statie	mg/l	7,0	-	-	1	0	60	SR EN 872:2009
Reziduu filtrabil	lesire statie	mg/l	403	-	-	1	0	2000	STAS 9187:1984
CBO5	lesire statie	mg/l	3	-	-	1	0	25	SR EN 1899-1:2003
Substanta Extractibila	lesire statie	mg/l	< 20	-	-	1	0	20	SR 7587:1996
Amoniu	lesire statie	mg/l	0,29	-	-	1	0	3	SR ISO 7150-1:200

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare – Nr. 1156/13.09.2021