

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL al treilea 2023

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **POIANA**- IULIE 2023


Tip proba-apa uzata

Indicator de analiza	Punct de Prelevare	U.M	Valoare inregistrata	Valoare maxima	Valoare minima	Numar masurat ori	Nr.depa siri CMA / VL	CMA/VL conform AGA nr.428/29.11.2022	Metoda de analiza
PH	lesire statie	Unit/PH	7,2	-	-	1	0	6,5-8,5	SR EN ISO10523-2012
CCO-CR	lesire statie	mg/l	39,07	-	-	1	0	125	SR ISO 6060/1996
Agenti de suprafata anionici	lesire statie	mg/l	0,41	-	-	1	0	0,5	SR EN 903:2003
MTS	lesire statie	mg/l	16	-	-	1	0	60	SR EN 872:2005
Reziduu filtrabil	lesire statie	mg/l	875	-	-	1	0	2000	STAS 9187:1984
CBO5	lesire statie	mg/l	8	-	-	1	0	25	SR EN ISO 5815-1:2020
Substanta Extractibila	lesire statie	mg/l	< 20	-	-	1	0	20	SR 7587:1996
Amoniu	lesire statie	mg/l	2,72	-	-	1	0	3	SR ISO 7150-1:2001

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare – Nr.905/10.07.2023



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **POIANA**- AUGUST 2023


Tip proba-apa uzata

Indicator de analiza	Punct de Prelevare	U.M	Valoare inregistrata	Valoare maxima	Valoare minima	Numar masurat ori	Nr.depasiri CMA / VL	CMA/VL conform AM nr.51/12.04.2023	Metoda de analiza
PH	lesire statie	Unit/PH	7,4	-	-	1	0	6,5-8,5	SR EN ISO10523-2012
CCO-CR	lesire statie	mg/l	34,56	-	-	1	0	125	SR ISO 6060/1996
Agenti de suprafata anionici	lesire statie	mg/l	0,12	-	-	1	0	0,5	SR EN 903:2003
MTS	lesire statie	mg/l	9,6	-	-	1	0	60	SR EN 872:2005
Reziduu filtrabil	lesire statie	mg/l	334	-	-	1	0	2000	STAS 9187:1984
CBO5	lesire statie	mg/l	16	-	-	1	0	25	SR EN ISO 5815-1:2020
Substanta Extractibila	lesire statie	mg/l	< 20	-	-	1	0	20	SR 7587:1996
Amoniu	lesire statie	mg/l	1,23	-	-	1	0	3	SR ISO 7150-1:2001

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform raport de incercare nr.1107/21.08.2023



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **POIANA**- SEPTEMBRIE 2023

Tip proba-apa uzata

Indicator de analiza	Punct de Prelevare	U.M	Valoare inregistrata	Valoare maxima	Valoare minima	Numar masurat ori	Nr.depa siri CMA / VL	CMA/VL conform AM nr.51/12.04.2023	Metoda de analiza
PH	lesire statie	Unit/PH	7,5	-	-	1	0	6,5-8,5	SR EN ISO10523-2012
CCO-CR	lesire statie	mg/l	34,73	-	-	1	0	125	SR ISO 6060/1996
Agenti de suprafata anionici	lesire statie	mg/l	0,11	-	-	1	0	0,5	SR EN 903:2003
MTS	lesire statie	mg/l	14	-	-	1	0	60	SR EN 872:2005
Reziduu filtrabil	lesire statie	mg/l	368	-	-	1	0	2000	STAS 9187:1984
CBO5	lesire statie	mg/l	10	-	-	1	0	25	SR EN ISO 5815-1:2020
Substanta Extractibila	lesire statie	mg/l	<20	-	-	1	0	20	SR 7587:1996
Amoniu	lesire statie	mg/l	0,93	-	-	1	0	3	SR ISO 7150-1:2001

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform raport de incercare nr.1241/18.09.2023