

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

[www.catd.ro](http://www.catd.ro) [secretariat@catd.ro](mailto:secretariat@catd.ro)

### REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL al treilea 2023

Indicatori chimici monitorizati la IESIREA din Statia de Epurare VISINESTI-AUGUST 2023

Tip proba-apa uzata

Indicator analizat	Punct de Prelevare	U.M	Val inregistrata	Val maxima	Val minima	Numar masuratori	Nr.depasiri CMA / VL	CMA / VL Conf.AM 46/24.03.2020	Metoda de analiza
Ph	lesire statie	Unitati Ph	7,5(20,0°C)	-	-	1	0	6,5-8,5	SR EN ISO 10523/2012
MTS	lesire statie	Mg/l	5,4	-	-	1	0	35	SR EN 872/2005
CBO <sub>5</sub>	lesire statie	mg/l	4	-	-	1	0	25	SR EN ISO 5815-1: 2020
CCO-Cr	lesire statie	mg/l	<30	-	-	1	0	125	SR EN ISO 6060/1996
SE	lesire statie	Mg/l	<20	-	-	1	0	20	SR ISO 7587/1996
Reziduu fix	lesire statie	Mg/l	354	-	-	1	0	2000	STAS 9187/84
Detergenti	lesire statie	Mg/l	<0,1	-	-	1	0	0,5	SR EN 903/2003
Amoniu	lesire statie	Mg/l	0,33	-	-	1	0	3	SR ISO 7150-1/2001

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare –nr. 1171/04.09.2023