

COMPANIA DE APA TARGOVISTE DAMBOVITA SA
DEPARTAMENTUL MANAGEMENT INTEGRAT CALITATE

Legea 458/2002(republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA TARGOVISTE

Laborator inregistrat la Ministerul Sanatatii - Certificat nr.662/25.07.2022 Str.Gaesti - Targoviste, Tel/Fax0245631472

BULETIN DE ANALIZA FIZICO – CHIMICA NR.3127

Solicitant: SECTIA TITU	Fisa prelevare nr: 3176
Loc de prelevare: Lunguletu iesire statie	Data si ora prelevarii probei: 10.10.2022/17:00
Punct prelevare: robinet rezervor stocare	Data si ora receptiei probei: 10.10.2022/18:30
Cod proba: 302	
Scopul analizei: verificarea calitatii apei – dezinfectie rezervor stocare ziua 1	Receptionat/inregistrat: Eftimie Gabriela
Produs analizat: apa potabila	Data si ora efectuarii analizei: 10.10.2022/19:00
Prelevat de: Eftimie Gabriela	Data si ora finalizarii analizei: 11.10.2022/04:00
	Data si ora eliberarii rezultatului: 11.10.2022/10:00

Metode de prelevare:ISO 5667-5/2017; SR EN ISO 5667-1/2022; SR EN ISO 5667-3/2018; SR EN ISO 5667-14/2017

Parametrii analizati	UM	Valoare CMA	Valoarea determinata	Metode de analiza
Concentratia ionilor de H	Unitati pH	$\geq 6,5 - \leq 9,5$	8,1/20,0°C	SR ISO 10523:2012
Conductivitate	$\mu S / cm$ la 20°C	2500	493	SR EN ISO 27888:1997
Turbiditate	NTU	≤ 5	0,33	SR EN ISO 7027-1:2016
Clor rezidual liber	mg/l	$\geq 0,1$ statie,rezervor $\geq 0,1 - \leq 0,5$ retea	0,46	SR EN ISO 7393-1:2002
Clor rezidual total	mg/l		0,51	SR EN ISO 7393-1:2002
Clor rezidual liber	%	min. 80% din clor total	90	-
Amoniu (NH ₄ ⁺)	mg/l	0,5	SLQ	SR ISO 7150-1:2001
Culoare	-	1)	1)	SR ISO 7887:2012 – metoda C
Miros	-	2)	2)	SR EN 1622:2007
Gust	-	3)	3)	SR EN 1622:2007
Nitrati (NO ₃ ⁻)	mg/l	50	5,180	SR ISO 7890-3:2000
Nitriti (NO ₂ ⁻)	mg/l	0,1 statie, rezervor 0,5 retea	SLQ	SR ISO 26777:2002 SR EN 26777:2002/C91:2006
Mangan	$\mu g/l$	50	42	SR ISO 6333:1997
Fier (Fe ²⁺ ,Fe ³⁺)	$\mu g/l$	200	89	SR ISO 6332:1996/C91:2006
Suma de calciu si magneziu	Grade Germane	Minim 5	13,24	SR ISO 6059:2008
Indice de permanganat	mgO ₂ /l	5	0,70	SR EN ISO 8467:2001
Cloruri (Cl ⁻)	mg/l	250	11,12	SR ISO 9297:2001
Sulfati	mg/l	250	30,72	STAS 3069:1987

1)Acceptabila consumatorilor si nicio modificare anormala 2)Acceptabil consumatorilor si niciun miros anormal 3) Acceptabil consumatorilor si niciun gust anormal

*Notatia SLQ = "sub limita de cuantificare a metodei"; LQ: amoniu<0,020mg/l; nitriti<0,009mg/l;

SEF LABORATOR,
Ing.chim.Sirbuletu Bogdan



RESPONSABIL ANALIZA,
Chim Tudorache Claudia

*Reproducerea buletinului de analiza fara acceptul scris al laboratorului este INTERZISA!
Rezultatul analizelor se refera numai la proba prelevata si analizata.*

COMPANIA DE APA TARGOVISTE DAMBOVITA SA
DEPARTAMENTUL MANAGEMENT INTEGRAT CALITATE

Legea 458/2002(republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA TARGOVISTE

Laborator inregistrat la Ministerul Sanatatii - Certificat nr. 662/25.07.2022 Str.Gaesti – Targoviste, Tel/fax.0245631472

BULETIN DE ANALIZA MICROBIOLOGICA NR.2998

Solicitant: SECTIA TITU Loc de prelevare: Lunguletu iesire statie Punct prelevare: robinet rezervor stocare Cod proba: 302 Scopul analizei: verificarea calitatii apei – dezinfectie rezervor stocare ziua 1 Produs analizat: apa potabila Prelevat de: Eftimie Gabriela	Fisa prelevare nr: 3176 Data si ora prelevarii probei: 10.10.2022/ 17:00 Data si ora receptiei probei: 10.10.2022/18:30 Receptionat/inregistrat: Eftimie Gabriela Data si ora efectuarii analizei: 10.10.2022/20:50 Data si ora finalizarii analizei: 13.10.2022/15:00 Data si ora eliberarii rezultatului: 13.10.2022/15:15
Metode de prelevare:ISO 5667-5/2017;SR EN ISO 5667-1/2022;SR EN ISO 5667-3/2018;SR EN ISO 19458/2007;SR EN ISO 5667-14/2017	

PARAMETRII MICROBIOLOGICI

Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Escherichia coli	UFC/100ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Enterococi intestinali	UFC/100ml	0	0	SR EN ISO 7899-2/2002

PARAMETRII INDICATORI

Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Bacterii coliforme	UFC/100ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Nr. de colonii la 22°C	UFC/1 ml	Nicio modificare anormala	1	SR EN ISO 6222/2004
Nr. de colonii la 37°C	UFC/1 ml	Nicio modificare anormala	0	SR EN ISO 6222/2004

SEF LABORATOR,
Ing.chim.Sirbuletu Bogdan



RESPOSABIL ANALIZA,
Biolog Dutu Florina

Reproducerea buletinului de analiza fara acceptul scris al laboratorului este **INTERZISA!**
Rezultatul analizelor se refera numai la proba prelevata si analizata.

COMPANIA DE APA TARGOVISTE DAMBOVITA SA
DEPARTAMENTUL MANAGEMENT INTEGRAT CALITATE

Legea 458/2002(republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA TARGOVISTE

Laborator inregistrat la Ministerul Sanatatii - Certificat nr.662/25.07.2022 Str.Gaesti - Targoviste, Tel/Fax0245631472

BULETIN DE ANALIZA FIZICO – CHIMICA NR.3128

Solicitant: SECTIA TITU Loc de prelevare: Lunguletu, str.Biruintei, nr.21A, Radescu Ion Punct prelevare: robinet cisterna Cod proba: 303 Scopul analizei: verificarea calitatii apei – dezinfectie rezervor stocare ziua 1 Produs analizat: apa potabila Prelevat de: Eftimie Gabriela	Fisa prelevare nr: 3177 Data si ora prelevarii probei: 10.10.2022/17:20 Data si ora receptiei probei: 10.10.2022/18:30 Receptionat/inregistrat: Eftimie Gabriela Data si ora efectuării analizei: 10.10.2022/19:00 Data si ora finalizării analizei: 10.10.2022/23:00 Data si ora eliberării rezultatului: 11.10.2022/10:00
---	--

Metode de prelevare:ISO 5667-5/2017; SR EN ISO 5667-1/2022; SR EN ISO 5667-3/2018; SR EN ISO 5667-14/2017

Parametrii analizati	UM	Valoare CMA	Valoarea determinata	Metode de analiza
Concentratia ionilor de H	Unitati pH	$\geq 6,5 - \leq 9,5$	8,0/20,0°C	SR ISO 10523:2012
Conductivitate	$\mu S / cm$ la 20°C	2500	498	SR EN ISO 27888:1997
Turbiditate	NTU	≤ 5	0,57	SR EN ISO 7027-1:2016
Clor rezidual liber	mg/l	$\geq 0,1$ statie,rezervor $\geq 0,1 - \leq 0,5$ retea	0,49	SR EN ISO 7393-1:2002
Clor rezidual total	mg/l		0,54	SR EN ISO 7393-1:2002
Clor rezidual liber	%	min. 80% din clor total	91	-
Amoniu (NH ₄ ⁺)	mg/l	0,5	SLQ	SR ISO 7150-1:2001
Culoare	-	1)	1)	SR ISO 7887:2012 – metoda C
Miros	-	2)	2)	SR EN 1622:2007
Gust	-	3)	3)	SR EN 1622:2007
Nitrati (NO ₃ ⁻)	mg/l	50	-	SR ISO 7890-3:2000
Nitriti (NO ₂ ⁻)	mg/l	0,1 statie, rezervor 0,5 retea	-	SR ISO 26777:2002 SR EN 26777:2002/C91:2006
Mangan	$\mu g/l$	50	43	SR ISO 6333:1997
Fier (Fe ²⁺ ,Fe ³⁺)	$\mu g/l$	200	100	SR ISO 6332:1996/C91:2006
Suma de calciu si magneziu	Grade Germane	Minim 5	-	SR ISO 6059:2008
Indice de permanganat	mgO ₂ /l	5	-	SR EN ISO 8467:2001
Cloruri (Cl ⁻)	mg/l	250	-	SR ISO 9297:2001
Sulfati	mg/l	250	-	STAS 3069:1987

1)Acceptabila consumatorilor si nicio modificare anormala 2)Acceptabil consumatorilor si niciun miros anormal 3) Acceptabil consumatorilor si niciun gust anormal

*Notatia SLQ = "sub limita de cuantificare a metodei"; LQ: amoniu<0,020mg/l;

SEF LABORATOR,
Ing.chim.Sirbuletu Bogdan



RESPONSABIL ANALIZA,
Chim Tudorache Claudia

*Reproducerea buletinului de analiza fara acceptul scris al laboratorului este INTERZISA!
Rezultatul analizelor se refera numai la proba prelevata si analizata.*

COMPANIA DE APA TARGOVISTE DAMBOVITA SA
DEPARTAMENTUL MANAGEMENT INTEGRAT CALITATE

Legea 458/2002(republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA TARGOVISTE

Laborator inregistrat la Ministerul Sanatatii - Certificat nr. 662/25.07.2022 Str.Gaesti – Targoviste, Tel/fax.0245631472

BULETIN DE ANALIZA MICROBIOLOGICA NR.2999

Solicitant: SECTIA TITU Loc de prelevare: Lunguletu, str.Biruintei, nr.21A, Radescu Ion Punct prelevare: robinet cisterna Cod proba: 303 Scopul analizei: verificarea calitatii apei – dezinfectie rezervor stocare ziua 1 Produs analizat: apa potabila Prelevat de: Eftimie Gabriela	Fisa prelevare nr: 3177 Data si ora prelevarii probei: 10.10.2022/ 17:20 Data si ora receptiei probei: 10.10.2022/18:30 Receptionat/inregistrat: Eftimie Gabriela Data si ora efectuarii analizei: 10.10.2022/20:50 Data si ora finalizarii analizei: 13.10.2022/15:00 Data si ora eliberarii rezultatului: 13.10.2022/15:15
Metode de prelevare:ISO 5667-5/2017;SR EN ISO 5667-1/2022;SR EN ISO 5667-3/2018;SR EN ISO 19458/2007;SR EN ISO 5667-14/2017	

PARAMETRII MICROBIOLOGICI

Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Escherichia coli	UFC/100ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Enterococi intestinali	UFC/100ml	0	0	SR EN ISO 7899-2/2002

PARAMETRII INDICATORI

Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Bacterii coliforme	UFC/100ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Nr. de colonii la 22°C	UFC/1 ml	Nicio modificare anormala	0	SR EN ISO 6222/2004
Nr. de colonii la 37°C	UFC/1 ml	Nicio modificare anormala	0	SR EN ISO 6222/2004

SEF LABORATOR,
Ing.chim.Sirbuletu Bogdan



RESPOSABIL ANALIZA,
Biolog Dutu Florina

Reproducerea buletinului de analiza fara acceptul scris al laboratorului este **INTERZISA!**
Rezultatul analizelor se refera numai la proba prelevata si analizata.

COMPANIA DE APA TARGOVISTE DAMBOVITA SA
DEPARTAMENTUL MANAGEMENT INTEGRAT CALITATE

Legea 458/2002(republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA TARGOVISTE

Laborator inregistrat la Ministerul Sanatatii - Certificat nr.662/25.07.2022 Str.Gaesti - Targoviste, Tel/Fax0245631472

BULETIN DE ANALIZA FIZICO – CHIMICA NR.3129

Solicitant: SECTIA TITU Loc de prelevare: Lunguletu, str.Bisericii, nr.14, Stan Marian Punct prelevare: robinet cisterna Cod proba: 304 Scopul analizei: verificarea calitatii apei – dezinfectie rezervor stocare ziua 1 Produs analizat: apa potabila Prelevat de: Eftimie Gabriela	Fisa prelevare nr: 3178 Data si ora prelevarii probei: 10.10.2022/17:40 Data si ora receptiei probei: 10.10.2022/18:30 Receptionat/inregistrat: Eftimie Gabriela Data si ora efectuării analizei: 10.10.2022/19:00 Data si ora finalizării analizei: 10.10.2022/23:00 Data si ora eliberării rezultatului: 11.10.2022/10:00
--	--

Metode de prelevare:ISO 5667-5/2017; SR EN ISO 5667-1/2022; SR EN ISO 5667-3/2018; SR EN ISO 5667-14/2017

Parametrii analizati	UM	Valoare CMA	Valoarea determinata	Metode de analiza
Concentratia ionilor de H	Unitati pH	$\geq 6,5 - \leq 9,5$	7,9/20,0°C	SR ISO 10523:2012
Conductivitate	$\mu S / cm$ la 20°C	2500	492	SR EN ISO 27888:1997
Turbiditate	NTU	≤ 5	0,58	SR EN ISO 7027-1:2016
Clor rezidual liber	mg/l	$\geq 0,1$ statie,rezervor $\geq 0,1 - \leq 0,5$ retea	0,47	SR EN ISO 7393-1:2002
Clor rezidual total	mg/l		0,51	SR EN ISO 7393-1:2002
Clor rezidual liber	%	min. 80% din clor total	92	-
Amoniu (NH ₄ ⁺)	mg/l	0,5	SLQ	SR ISO 7150-1:2001
Culoare	-	1)	1)	SR ISO 7887:2012 – metoda C
Miros	-	2)	2)	SR EN 1622:2007
Gust	-	3)	3)	SR EN 1622:2007
Nitrati (NO ₃ ⁻)	mg/l	50	-	SR ISO 7890-3:2000
Nitriti (NO ₂ ⁻)	mg/l	0,1 statie, rezervor 0,5 retea	-	SR ISO 26777:2002 SR EN 26777:2002/C91:2006
Mangan	$\mu g/l$	50	46	SR ISO 6333:1997
Fier (Fe ²⁺ ,Fe ³⁺)	$\mu g/l$	200	84	SR ISO 6332:1996/C91:2006
Suma de calciu si magneziu	Grade Germane	Minim 5	-	SR ISO 6059:2008
Indice de permanganat	mgO ₂ /l	5	-	SR EN ISO 8467:2001
Cloruri (Cl ⁻)	mg/l	250	-	SR ISO 9297:2001
Sulfati	mg/l	250	-	STAS 3069:1987

1)Acceptabila consumatorilor si nicio modificare anormala 2)Acceptabil consumatorilor si niciun miros anormal 3) Acceptabil consumatorilor si niciun gust anormal

*Notatia SLQ = "sub limita de cuantificare a metodei"; LQ: amoniu<0,020mg/l;

SEF LABORATOR,
Ing.chim.Sirbuletu Bogdan



RESPONSABIL ANALIZA,
Chim Tudorache Claudia

*Reproducerea buletinului de analiza fara acceptul scris al laboratorului este INTERZISA!
Rezultatul analizelor se refera numai la proba prelevata si analizata.*

COMPANIA DE APA TARGOVISTE DAMBOVITA SA
DEPARTAMENTUL MANAGEMENT INTEGRAT CALITATE

Legea 458/2002(republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA TARGOVISTE

Laborator inregistrat la Ministerul Sanatatii - Certificat nr. 662/25.07.2022 Str.Gaesti – Targoviste, Tel/fax.0245631472

BULETIN DE ANALIZA MICROBIOLOGICA NR.3000

Solicitant: SECTIA TITU Loc de prelevare: Lunguletu, str.Bisericii, nr.14, Stan Marian Punct prelevare: robinet cisterna Cod proba: 304 Scopul analizei: verificarea calitatii apei – dezinfectie rezervor stocare ziua 1 Produs analizat: apa potabila Prelevat de: Eftimie Gabriela	Fisa prelevare nr: 3178 Data si ora prelevarii probei: 10.10.2022/ 17:40 Data si ora receptiei probei: 10.10.2022/18:30 Receptionat/inregistrat: Eftimie Gabriela Data si ora efectuarii analizei: 10.10.2022/20:50 Data si ora finalizarii analizei: 13.10.2022/15:00 Data si ora eliberarii rezultatului: 13.10.2022/15:15
Metode de prelevare:ISO 5667-5/2017;SR EN ISO 5667-1/2022;SR EN ISO 5667-3/2018;SR EN ISO 19458/2007;SR EN ISO 5667-14/2017	

PARAMETRII MICROBIOLOGICI

Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Escherichia coli	UFC/100ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Enterococi intestinali	UFC/100ml	0	0	SR EN ISO 7899-2/2002

PARAMETRII INDICATORI

Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Bacterii coliforme	UFC/100ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Nr. de colonii la 22°C	UFC/1 ml	Nicio modificare anormala	0	SR EN ISO 6222/2004
Nr. de colonii la 37°C	UFC/1 ml	Nicio modificare anormala	1	SR EN ISO 6222/2004

SEF LABORATOR,
Ing.chim.Sirbuletu Bogdan



RESPOSABIL ANALIZA,
Biolog Dutu Florina

Reproducerea buletinului de analiza fara acceptul scris al laboratorului este **INTERZISA!**
Rezultatul analizelor se refera numai la proba prelevata si analizata.

COMPANIA DE APA TARGOVISTE DAMBOVITA SA
DEPARTAMENTUL MANAGEMENT INTEGRAT CALITATE

Legea 458/2002(Republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA TARGOVISTE

Laborator inregistrat la Ministerul Sanatatii - Certificat nr.662/25.07.2022 Str.Gaesti - Targoviste, Tel/Fax0245631472

BULETIN DE ANALIZA FIZICO – CHIMICA NR.3155

Solicitant: SECTIA TITU Loc de prelevare: Lunguletu iesire statie Punct prelevare: robinet chiuveta statie Cod proba: 307 Scopul analizei: verificarea calitatii apei – dezinfectie rezervor stocare ziua 2 Produs analizat: apa potabila Prelevat de: Lixandru Gabriela	Fisa prelevare nr: 3201 Data si ora prelevarii probei: 11.10.2022/17:20 Data si ora receptiei probei: 11.10.2022/19:20 Receptionat/inregistrat: Eftimie Gabriela Data si ora efectuării analizei: 11.10.2022/19:30 Data si ora finalizării analizei: 12.10.2022/02:00 Data si ora eliberării rezultatului: 12.10.2022/10:00
---	--

Metode de prelevare:ISO 5667-5/2017; SR EN ISO 5667-1/2022; SR EN ISO 5667-3/2018; SR EN ISO 5667-14/2017

Parametrii analizati	UM	Valoare CMA	Valoarea determinata	Metode de analiza
Concentratia ionilor de H	Unitati pH	$\geq 6,5 - \leq 9,5$	8,0/20,0°C	SR ISO 10523:2012
Conductivitate	$\mu S / cm$ la 20°C	2500	473	SR EN ISO 27888:1997
Turbiditate	NTU	≤ 5	0,53	SR EN ISO 7027-1:2016
Clor rezidual liber	mg/l	$\geq 0,1$ statie, rezervor $\geq 0,1 - \leq 0,5$ retea	0,27	SR EN ISO 7393-1:2002
Clor rezidual total	mg/l		0,29	SR EN ISO 7393-1:2002
Clor rezidual liber	%	min. 80% din clor total	93	-
Amoniu (NH ₄ ⁺)	mg/l	0,5	SLQ	SR ISO 7150-1:2001
Culoare	-	1)	1)	SR ISO 7887:2012 – metoda C
Miros	-	2)	2)	SR EN 1622:2007
Gust	-	3)	3)	SR EN 1622:2007
Nitrati (NO ₃ ⁻)	mg/l	50	-	SR ISO 7890-3:2000
Nitriti (NO ₂ ⁻)	mg/l	0,1 statie, rezervor 0,5 retea	-	SR ISO 26777:2002 SR EN 26777:2002/C91:2006
Mangan	$\mu g/l$	50	36	SR ISO 6333:1997
Fier (Fe ²⁺ , Fe ³⁺)	$\mu g/l$	200	126	SR ISO 6332:1996/C91:2006
Suma de calciu si magneziu	Grade Germane	Minim 5	-	SR ISO 6059:2008
Indice de permanganat	mgO ₂ /l	5	-	SR EN ISO 8467:2001
Cloruri (Cl ⁻)	mg/l	250	-	SR ISO 9297:2001
Sulfati	mg/l	250	-	STAS 3069:1987

1)Acceptabila consumatorilor si nicio modificare anormala 2)Acceptabil consumatorilor si niciun miros anormal 3) Acceptabil consumatorilor si niciun gust anormal

*Notatia SLQ = "sub limita de cuantificare a metodei"; LQ: amoniu<0,020mg/l;

SEF LABORATOR,
Ing.chim.Sirbuletu Bogdan



RESPONSABIL ANALIZA,
Chim Tudorache Claudia

*Reproducerea buletinului de analiza fara acceptul scris al laboratorului este INTERZISA!
Rezultatul analizelor se refera numai la proba prelevata si analizata.*

COMPANIA DE APA TARGOVISTE DAMBOVITA SA
DEPARTAMENTUL MANAGEMENT INTEGRAT CALITATE

Legea 458/2002(republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA TARGOVISTE

Laborator inregistrat la Ministerul Sanatatii - Certificat nr. 662/25.07.2022 Str.Gaesti – Targoviste, Tel/fax.0245631472

BULETIN DE ANALIZA MICROBIOLOGICA NR.3021

Solicitant: SECTIA TITU Loc de prelevare: Lunguletu iesire statie Punct prelevare: robinet chiuvea statie Cod proba: 307 Scopul analizei: verificarea calitatii apei – dezinfectie rezervor stocare ziua 2 Produs analizat: apa potabila Prelevat de: Lixandru Gabriela	Fisa prelevare nr: 3201 Data si ora prelevarii probei: 11.10.2022/17:20 Data si ora receptiei probei: 11.10.2022/19:20 Receptionat/inregistrat: Eftimie Gabriela Data si ora efectuării analizei: 11.10.2022/23:00 Data si ora finalizării analizei: 14.10.2022/20:00 Data si ora eliberării rezultatului: 17.10.2022/10:00
Metode de prelevare:ISO 5667-5/2017;SR EN ISO 5667-1/2022;SR EN ISO 5667-3/2018;SR EN ISO 19458/2007;SR EN ISO 5667-14/2017	

PARAMETRII MICROBIOLOGICI

Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Escherichia coli	UFC/100ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Enterococi intestinali	UFC/100ml	0	0	SR EN ISO 7899-2/2002

PARAMETRII INDICATORI

Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Bacterii coliforme	UFC/100ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Nr. de colonii la 22°C	UFC/1 ml	Nicio modificare anormala	0	SR EN ISO 6222/2004
Nr. de colonii la 37°C	UFC/1 ml	Nicio modificare anormala	1	SR EN ISO 6222/2004

SEF LABORATOR,
Ing.chim.Sirbuletu Bogdan

RESPOSABIL ANALIZA,
Biolog Dutu Florina



Reproducerea buletinului de analiza fara acceptul scris al laboratorului este **INTERZISA!**
Rezultatul analizelor se refera numai la proba prelevata si analizata.

COMPANIA DE APA TARGOVISTE DAMBOVITA SA
DEPARTAMENTUL MANAGEMENT INTEGRAT CALITATE

Legea 458/2002(republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA TARGOVISTE

Laborator inregistrat la Ministerul Sanatatii - Certificat nr.662/25.07.2022 Str.Gaesti - Targoviste, Tel/Fax0245631472

BULETIN DE ANALIZA FIZICO – CHIMICA NR.3156

Solicitant: SECTIA TITU Loc de prelevare: Lunguletu, str.Biruintei, nr.21A, Radescu Ion Punct prelevare: robinet cisterna Cod proba: 308 Scopul analizei: verificarea calitatii apei – dezinfectie rezervor stocare ziua 2 Produs analizat: apa potabila Prelevat de: Lixandru Gabriela	Fisa prelevare nr: 3202 Data si ora prelevarii probei: 11.10.2022/17:35 Data si ora receptiei probei: 11.10.2022/19:20 Receptionat/inregistrat: Eftimie Gabriela Data si ora efectuării analizei: 11.10.2022/19:30 Data si ora finalizării analizei: 12.10.2022/02:00 Data si ora eliberării rezultatului: 12.10.2022/10:00
--	--

Metode de prelevare:ISO 5667-5/2017; SR EN ISO 5667-1/2022; SR EN ISO 5667-3/2018; SR EN ISO 5667-14/2017

Parametrii analizati	UM	Valoare CMA	Valoarea determinata	Metode de analiza
Concentratia ionilor de H	Unitati pH	$\geq 6,5 - \leq 9,5$	8,0/20,0°C	SR ISO 10523:2012
Conductivitate	$\mu S / cm$ la 20°C	2500	472	SR EN ISO 27888:1997
Turbiditate	NTU	≤ 5	0,55	SR EN ISO 7027-1:2016
Clor rezidual liber	mg/l	$\geq 0,1$ statie,rezervor $\geq 0,1 - \leq 0,5$ retea	0,29	SR EN ISO 7393-1:2002
Clor rezidual total	mg/l		0,30	SR EN ISO 7393-1:2002
Clor rezidual liber	%	min. 80% din clor total	90	-
Amoniu (NH ₄ ⁺)	mg/l	0,5	SLQ	SR ISO 7150-1:2001
Culoare	-	1)	1)	SR ISO 7887:2012 – metoda C
Miros	-	2)	2)	SR EN 1622:2007
Gust	-	3)	3)	SR EN 1622:2007
Nitrati (NO ₃ ⁻)	mg/l	50	-	SR ISO 7890-3:2000
Nitriti (NO ₂ ⁻)	mg/l	0,1 statie, rezervor 0,5 retea	-	SR ISO 26777:2002 SR EN 26777:2002/C91:2006
Mangan	$\mu g/l$	50	36	SR ISO 6333:1997
Fier (Fe ²⁺ ,Fe ³⁺)	$\mu g/l$	200	127	SR ISO 6332:1996/C91:2006
Suma de calciu si magneziu	Grade Germane	Minim 5	-	SR ISO 6059:2008
Indice de permanganat	mgO ₂ /l	5	-	SR EN ISO 8467:2001
Cloruri (Cl ⁻)	mg/l	250	-	SR ISO 9297:2001
Sulfati	mg/l	250	-	STAS 3069:1987

1)Acceptabila consumatorilor si nicio modificare anormala 2)Acceptabil consumatorilor si niciun miros anormal 3) Acceptabil consumatorilor si niciun gust anormal

*Notatia SLQ = "sub limita de cuantificare a metodei"; LQ: amoniu<0,020mg/l;

SEF LABORATOR,
Ing.chim.Sirbulu Bogdan



RESPONSABIL ANALIZA,
Chim Tudorache Claudia

*Reproducerea buletinului de analiza fara deceptul scris al laboratorului este INTERZISA!
Rezultatul analizelor se refera numai la proba prelevata si analizata.*

COMPANIA DE APA TARGOVISTE DAMBOVITA SA
DEPARTAMENTUL MANAGEMENT INTEGRAT CALITATE

Legea 458/2002(republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA TARGOVISTE

Laborator inregistrat la Ministerul Sanatatii - Certificat nr. 662/25.07.2022 Str.Gaesti – Targoviste, Tel/fax.0245631472

BULETIN DE ANALIZA MICROBIOLOGICA NR.3022

Solicitant: SECTIA TITU Loc de prelevare: Lunguletu, str.Biruintei, nr.21A, Radescu Ion Punct prelevare: robinet cisterna Cod proba: 308 Scopul analizei: verificarea calitatii apei – dezinfectie rezervor stocare ziua 1 Produs analizat: apa potabila Prelevat de: Lixandru Gabriela	Fisa prelevare nr: 3202 Data si ora prelevarii probei: 11.10.2022/17:35 Data si ora receptiei probei: 11.10.2022/19:20 Receptionat/inregistrat: Eftimie Gabriela Data si ora efectuarii analizei: 11.10.2022/23:00 Data si ora finalizarii analizei: 14.10.2022/20:00 Data si ora eliberarii rezultatului: 17.10.2022/10:00
Metode de prelevare:ISO 5667-5/2017;SR EN ISO 5667-1/2022;SR EN ISO 5667-3/2018;SR EN ISO 19458/2007;SR EN ISO 5667-14/2017	

PARAMETRII MICROBIOLOGICI

Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Escherichia coli	UFC/100ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Enterococi intestinali	UFC/100ml	0	0	SR EN ISO 7899-2/2002

PARAMETRII INDICATORI

Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Bacterii coliforme	UFC/100ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Nr. de colonii la 22°C	UFC/1 ml	Nicio modificare anormala	1	SR EN ISO 6222/2004
Nr. de colonii la 37°C	UFC/1 ml	Nicio modificare anormala	3	SR EN ISO 6222/2004

SEF LABORATOR,
Ing.chim.Sirbuletu Bogdan



RESPOSABIL ANALIZA,
Biolog Dutu Florina

Reproducerea buletinului de analiza fara acceptul scris al laboratorului este **INTERZISA!**
Rezultatul analizelor se refera numai la proba prelevata si analizata.

COMPANIA DE APA TARGOVISTE DAMBOVITA SA
DEPARTAMENTUL MANAGEMENT INTEGRAT CALITATE

Legea 458/2002(republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA TARGOVISTE

Laborator inregistrat la Ministerul Sanatatii - Certificat nr.662/25.07.2022 Str.Gaesti - Targoviste, Tel/Fax0245631472

BULETIN DE ANALIZA FIZICO – CHIMICA NR.3157

Solicitant: SECTIA TITU Loc de prelevare: Lunguletu, str.Bisericii, nr.14, Stan Marian Punct prelevare: robinet cisterna Cod proba: 309 Scopul analizei: verificarea calitatii apei – dezinfectie rezervor stocare ziua 2 Produs analizat: apa potabila Prelevat de: Lixandru Gabriela	Fisa prelevare nr: 3203 Data si ora prelevarii probei: 11.10.2022/17:45 Data si ora receptiei probei: 11.10.2022/19:20 Receptionat/inregistrat: Eftimie Gabriela Data si ora efectuării analizei: 11.10.2022/19:30 Data si ora finalizării analizei: 12.10.2022/02:00 Data si ora eliberării rezultatului: 12.10.2022/10:00
---	--

Metode de prelevare:ISO 5667-5/2017; SR EN ISO 5667-1/2022; SR EN ISO 5667-3/2018; SR EN ISO 5667-14/2017

Parametrii analizati	UM	Valoare CMA	Valoarea determinata	Metode de analiza
Concentratia ionilor de H	Unitati pH	$\geq 6,5 - \leq 9,5$	8,0/20,0°C	SR ISO 10523:2012
Conductivitate	$\mu S / cm$ la 20°C	2500	463	SR EN ISO 27888:1997
Turbiditate	NTU	≤ 5	0,54	SR EN ISO 7027-1:2016
Clor rezidual liber	mg/l	$\geq 0,1$ statie,rezervor $\geq 0,1 - \leq 0,5$ retea	0,20	SR EN ISO 7393-1:2002
Clor rezidual total	mg/l		0,22	SR EN ISO 7393-1:2002
Clor rezidual liber	%	min. 80% din clor total	90	-
Amoniu (NH ₄ ⁺)	mg/l	0,5	SLQ	SR ISO 7150-1:2001
Culoare	-	1)	1)	SR ISO 7887:2012 – metoda C
Miros	-	2)	2)	SR EN 1622:2007
Gust	-	3)	3)	SR EN 1622:2007
Nitrati (NO ₃ ⁻)	mg/l	50	-	SR ISO 7890-3:2000
Nitriti (NO ₂ ⁻)	mg/l	0,1 statie, rezervor 0,5 retea	-	SR ISO 26777:2002 SR EN 26777:2002/C91:2006
Mangan	$\mu g/l$	50	31	SR ISO 6333:1997
Fier (Fe ²⁺ ,Fe ³⁺)	$\mu g/l$	200	134	SR ISO 6332:1996/C91:2006
Suma de calciu si magneziu	Grade Germane	Minim 5	-	SR ISO 6059:2008
Indice de permanganat	mgO ₂ /l	5	-	SR EN ISO 8467:2001
Cloruri (Cl ⁻)	mg/l	250	-	SR ISO 9297:2001
Sulfati	mg/l	250	-	STAS 3069:1987

1)Acceptabila consumatorilor si nicio modificare anormala 2)Acceptabil consumatorilor si niciun miros anormal 3) Acceptabil consumatorilor si niciun gust anormal

*Notatia SLQ = "sub limita de cuantificare a metodei"; LQ: amoniu<0,020mg/l;

SEF LABORATOR,
Ing.chim.Sirbuletu Bogdan



RESPONSABIL ANALIZA,
Chim Tudorache Claudia

Reproducerea buletinului de analiza fara acceptul scris al laboratorului este INTERZISA!
Rezultatul analizelor se refera numai la proba prelevata si analizata.

COMPANIA DE APA TARGOVISTE DAMBOVITA SA
DEPARTAMENTUL MANAGEMENT INTEGRAT CALITATE

Legea 458/2002(republicata) privind calitatea apei potabile-modificata si completata cu Ordonanta 22/2017

LABORATOR APA POTABILA TARGOVISTE

Laborator inregistrat la Ministerul Sanatatii - Certificat nr. 662/25.07.2022 Str.Gaesti – Targoviste, Tel/fax.0245631472

BULETIN DE ANALIZA MICROBIOLOGICA NR.3023

Solicitant: SECTIA TITU Loc de prelevare: Lunguletu, str.Bisericii, nr.14, Stan Marian Punct prelevare: robinet cisterna Cod proba: 309 Scopul analizei: verificarea calitatii apei – dezinfectie rezervor stocare ziua 2 Produs analizat: apa potabila Prelevat de: Lixandru Gabriela	Fisa prelevare nr: 3203 Data si ora prelevarii probei: 11.10.2022/17:45 Data si ora receptiei probei: 11.10.2022/19:20 Receptionat/inregistrat: Eftimie Gabriela Data si ora efectuarii analizei: 11.10.2022/23:00 Data si ora finalizarii analizei: 14.10.2022/20:00 Data si ora eliberarii rezultatului: 17.10.2022/10:00
Metode de prelevare:ISO 5667-5/2017;SR EN ISO 5667-1/2022;SR EN ISO 5667-3/2018;SR EN ISO 19458/2007;SR EN ISO 5667-14/2017	

PARAMETRII MICROBIOLOGICI

Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Escherichia coli	UFC/100ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Enterococi intestinali	UFC/100ml	0	0	SR EN ISO 7899-2/2002

PARAMETRII INDICATORI

Parametrii analizati	UM	Valoare CMA	Valoare determinata	Metode de analiza
Bacterii coliforme	UFC/100ml	0	0	SR EN ISO 9308-1:2015 SR EN ISO 9308-1:2015/A1:2017
Nr. de colonii la 22°C	UFC/1 ml	Nicio modificare anormala	2	SR EN ISO 6222/2004
Nr. de colonii la 37°C	UFC/1 ml	Nicio modificare anormala	6	SR EN ISO 6222/2004

SEF LABORATOR,
Ing.chim.Sirbuletu Bogdan



RESPOSABIL ANALIZA,
Biolog Dutu Florina

Reproducerea buletinului de analiza fara acceptul scris al laboratorului este **INTERZISA!**
Rezultatul analizelor se refera numai la proba prelevata si analizata.